



1. BRANCH PIPING (SUPPLY & RETURN) SHALL BE SIZED AS NOTED BELOW. CONNECT PIPING TO UNIT COIL (CHW & HW) AND PROVIDE ALL VALVING AND ACCESSORIES AS DETAILED. REFER TO SCHEDULE FOR COIL GPM.
2. INSTALL SECONDARY DRAIN PAN UNDER ALL PIPING AND EQUIPMENT INSTALLED IN UTILITY SPACES (ELECTRIC, ELEVATOR, IDF, A/V, ETC.). RUN OVERFLOW TO DRAIN OVER NEAREST OCCUPIED SPACE OR CORRIDOR.
3. ALL COILING COIL CONDENSATE DRAIN PIPING SHALL BE SLOPED 1/8" PER FOOT.
4. ALL DRAIN CONNECTIONS SHALL BE 45° IN THE DIRECTION OF THE CONDENSATE FLOW.
- OTHERWISE NOTED.
- GENERAL PIPING NOTES:
1. PROVIDE CONDENSATE PUMP FOR UNITS WITH COILING COILS THAT WILL NOT DRAIN BY GRAVITY. (SIMILAR TO LITTLE GIANT, MODEL VKMA-15ULT, 115/1/60/A, 1/60HP). COORDINATE LOCATIONS WITH ELECTRICAL CONTRACTOR.
2. ALL COILING COIL CONDENSATE DRAIN PIPING SHALL BE SLOPED 1/8" PER FOOT.
3. ALL DRAIN PIPING FROM UNIT TO MAIN BRANCH SHALL BE FULL SIZE OF UNIT DRAIN CONNECTION UNLESS OTHERWISE NOTED.
4. ALL DRAIN CONNECTIONS SHALL BE 45° IN THE DIRECTION OF THE CONDENSATE FLOW.

PROJECT NUMBER		07087 LEVEL 117
DRAWN BY		SG
CHECKED BY		RR
ISSUE DATE		16 JULY 07
SCALE		1/4" = 1'-0"

THE PALAZZO
LIDO CASINO RESORT, LLC
STEFANO CANTURI
PROJECT #07087
3251 LAS VEGAS BOULEVARD SOUTH
LAS VEGAS, NV 89109

WESTAR ARCHITECTS
WESTAR Architectural Group/Nevada, Inc.
ARCHITECTURAL PLANNING - INTERIOR DESIGN
701 BRIDGE AVENUE SUITE 400 LAS VEGAS, NEVADA 89101
TELEPHONE: (702) 878-0000 FAX: (702) 878-8430
WWW.WESTARCHITECTS.COM

SEAL