

## LIGHTING FIXTURE SCHEDULE

### FIXTURE SCHEDULE GENERAL NOTES:

1. FIXTURES SHALL HAVE APPROPRIATE UL LABEL, DAMP, OR WET AS REQUIRED BY CODES AND ORDINANCES.
2. FIXTURES SHALL INCLUDE ALL ACCESSORIES NECESSARY FOR INSTALLATION ACCORDING TO MANUFACTURER'S SHOP DRAWINGS AND AS REQUIRED BY CODES AND LOCAL ORDINANCES.
3. PRIOR TO ORDERING ANY LIGHTING EQUIPMENT, THE CONTRACTOR SHALL COORDINATE ALL FIXTURE LOCATIONS WITH ARCHITECTURAL REFLECTED CEILING PLANS AND CEILING CAVITY DEPTHS.
4. ALL LAMPS SHALL BE PROVIDED AND INSTALLED ACCORDING TO THE ATTACHED FIXTURE SCHEDULE AND SPECIFICATIONS. ENSURE COMPATIBILITY BETWEEN FIXTURE, LAMP AND BALLAST(S). (OSRAM SYLVANIA SERIES)
5. CONTRACTOR SHALL VERIFY FIXTURE VOLTAGES AND CEILING TRIM COMPATIBILITY PRIOR TO ORDERING FIXTURES.
6. PROVIDE APPROVED FIRE-RATED ENCLOSURES FOR ALL LIGHTING FIXTURES LOCATED IN FIRE-RATED CEILINGS.
7. LIGHTING FIXTURE CATALOG NUMBERS ARE SERIES TYPE ONLY. PROVIDE ALL NECESSARY HARDWARE AS REQUIRED BY THE SPECIFICATIONS, DRAWINGS, AND PROJECT CONDITIONS FOR A COMPLETE INSTALLATION.
8. ALL FIXTURES SHALL BE ORDERED WITH APPROPRIATE BALLAST(S) THAT HAVE UL AND CBM LABELS. ALL BALLASTS MUST CONFORM TO TITLE 24 REQUIREMENTS FOR PERFORMANCE. PROVIDE MULTIPLE BALLASTS FOR DUAL-LEVEL SWITCHING AND WIRING (1A, TANDEN) AS INDICATED ON THE PLANS.
9. UPON INITIAL ENERGIZING OF ALL NEW FLUORESCENT LAMPS, A CONTINUOUS PERIOD OF 30 HOURS SHALL OCCUR PRIOR TO DE-ENERGIZING OF LAMPS, FOR MANUFACTURER REQUIRED LAMP BURN-IN AND MAXIMUM LAMP LIFE.
10. ALL FLUORESCENT BALLASTS SHALL BE ELECTRONIC TYPE. PROVIDE END OF LIFE (EOL) SHUT-DOWN PROTECTION FOR COMPACT FLUORESCENT LAMPS.
11. ENSURE COMPATIBILITY OF ALL LIGHTING SYSTEM COMPONENTS ESPECIALLY DIMMED SYSTEMS. FIXTURES, LAMPS, BALLAST(S), AND DIMMING SYSTEMS/INDIVIDUAL CONTROLS MUST BE FACTORY CERTIFIED COMPATIBLE FOR FULL RANGE OF DIMMING COMPATIBILITY.
12. PROVIDE CLEARANCES FROM COMBUSTIBLES A MINIMUM OF 1/2" (OTHER THAN AT POINTS OF SUPPORT) AND 3" FROM INSULATION FOR RECESSED LIGHTING FIXTURES WHICH ARE NON-IC RATED.
13. PROVIDE A MINIMUM OF TWO (2) #2 SUPPORT WIRES ATTACHED TO BUILDING FRAME IN ADDITION TO T-BAR CLIPS FOR FLUORESCENT FIXTURES RECESSED IN SUSPENDED T-BAR CEILING.
14. FIXTURES WITH EMERGENCY BATTERY BACKUP SHALL BE WIRED AHEAD OF ANY LOCAL SWITCHING IN COMPLIANCE WITH NEC ARTICLE 100.
15. EMERGENCY LIGHTING UNITS SHALL BE EQUIPPED WITH FACTORY-INSTALLED INTEGRAL TEST SWITCHES.
16. PROVIDE DOOR-TO-FRAME AND LENS-TO-DOOR GASKETING, INVERTED LENS, AND FOOD SERVICE RATING FOR ALL FIXTURES LOCATED IN FOOD SERVICE AREAS.

TYPE	DESCRIPTION AND MANUFACTURER	NOTES
A1 5W/FT	SURFACE MOUNTED LED FLEXIBLE STRIPLIGHT WITH WARM WHITE COLOR AND LED SPACING AT 2" CENTERS. PROVIDE WITH POWER SUPPLY FOR A COMPLETE AND OPERABLE SYSTEM. VOLTAGE: 120V LAMP: LED INCLUDED MANUFACTURER: GE *TETRA SERIES	
A2 30	SEMI-RECESSED LOW VOLTAGE BUTTON LIGHT WITH 1 LAMP AND ELECTRONIC TRANSFORMER. FINISH TO BE SPECIFIED BY OWNER. VOLTAGE: 120V LAMP: INCLUDED WITH FIXTURE MANUFACTURER: WAC *HR-88	
A3 15	4" DIAMETER RECESSED LOW VOLTAGE DOWNLIGHT WITH 1 LAMP AND ELECTRONIC TRANSFORMER. VOLTAGE: 120V LAMP: (1) T5W, MR16, NFL MANUFACTURER: LITHONIA * DLV-DUN-MR16-4-AC-120	
A4 15	4" DIAMETER RECESSED LOW VOLTAGE WALLWASH WITH 1 LAMP AND ELECTRONIC TRANSFORMER. VOLTAGE: 120V LAMP: (1) T5W, MR16, NFL MANUFACTURER: LITHONIA * DLV-WSH-MR16-4-AC-120	
B1 30	6" DIAMETER RECESSED ADJUSTABLE DOWNLIGHT WITH CLEAR ALZAK REFLECTOR. VOLTAGE: 120V LAMP: (1) T0W MH MANUFACTURER: LITHONIA * DPH-F30-10MHC-6AC-T00-120	
B2 50	6" DIAMETER RECESSED ADJUSTABLE DOWNLIGHT WITH CLEAR ALZAK REFLECTOR. VOLTAGE: 120V LAMP: (1) 39W MH MANUFACTURER: LITHONIA * DPH-F30-39MHC-6AC-T00-120	
DL1 300	DECORATIVE PENDANT MOUNTED IN RETAIL AREA. FIXTURE SHALL BE OWNER FURNISHED, CONTRACTOR INSTALLED. VOLTAGE: 120V LAMP: TO BE SELECTED BY INTERIOR DESIGNER MANUFACTURER: TO BE SELECTED BY INTERIOR DESIGNER	
F1 25	2' FLUORESCENT STRIP WITH 1 LAMP AND ELECTRONIC BALLAST. VOLTAGE: 120V LAMP: (1) F01T, T8, 3000K MANUFACTURER: LITHONIA * 2UC-1T-120	
X1 10	EDGE LIT EXIT SIGN WITH LED LAMPS, BRASS HOUSING, RED ON MIRROR BACKGROUND AND INTEGRAL EMERGENCY BATTERY. VOLTAGE: 120V LAMP: LED (INCLUDED) MANUFACTURER: LITHONIA * LRP-B8-1-RMR-120/21T-ELN	
Z1 100	RECESSED MOUNTED EMERGENCY LIGHT WITH 2 LAMPS AND INTEGRAL EMERGENCY BATTERY. PAINT FIXTURE TO MATCH ADJACENT CEILING FINISH. VOLTAGE: 120V LAMP: (2) 50W, MR16, NFL MANUFACTURER: CONCEALITE *F5-50-90-PT-120	



# ESTAR ARCHITECTS

WESTAR Architectural Group/Nevada, Inc  
**ARCHITECTURE • PLANNING • INTERIOR DESIGN**  
701 BRIDGER AVENUE SUITE 400 LAS VEGAS, NEVADA 89101  
TELEPHONE: (702) 878-0000 FAX: (702) 878-9430  
[www.waganarchitects.com](http://www.waganarchitects.com)

**THE PALAZZO  
LIDO CASINO RESORT, LLC  
STEFANO CANTURI**

**STEFANO CANTURI**

PROJECT NUMBER		L07233		NUMBER	REVISION DESCRIPTION	DATE
DRAWN BY:		CHECKED BY:				
MSA		DM				
ISSUE DATE		07.16.07				
SCALE		AS NOTED				

## E0.02

### LIGHTING FIXTURE SCHEDULE

## PERMIT SET